



NOTES:

- ANY CURB STOP LOCATED IN BLACKTOP OR CONCRETE DRIVEWAY OR SIDEWALK SHALL BE COVERED WITH A 10" G.V. BOX TOP SECTION.
- ALL WATER SERVICES SHALL BE 1" SDR 11 HDPE BLACK POLY.
- ALL NEW WATER SERVICES INSTALLED SHALL USE A SMITH-BLAIR 372 STAINLESS STEEL SADDLE.
- CORPORATION SHALL BE A 1" FORD FB 600-4-NL, MCDONALD 74701-B, MUELLER B-25000-N OR OWNER APPROVED ALTERNATE.
- CURB STOP AND BOX SHALL BE 1" FORD B22-444-M-NL, MCDONALD 76104, MUELLER B-25154 OR OWNER APPROVED ALTERNATE WITH A STATIONARY ROD AND BE ABLE TO ADJUST FROM 84" TO 96".
- WATER SERVICE MUST BE CONTINUOUS WITH NO JOINTS.
- SANITARY AND WATER SERVICE LINES SHALL BE INSTALLED IN THE SAME TRENCH WITH 3 FEET OF SEPARATION, WATER SERVICE ON UPSTREAM SIDE OF SANITARY SERVICE.
- CURB BOXES INSTALLED IN AREAS WHERE THE BOULEVARD IS TO BE CUT AT A LATER DATE, TOP OF CURB BOX SHALL BE SAME ELEVATION AS TOP OF CURB.

| | | |
|---|---|-----------------------------|
|  City of Maple Grove | 1" WATER SERVICE WITH PVC WATERMAIN | STANDARD PLATE # WM-7 |
| | CITY OF MAPLE GROVE ENGINEERING & PUBLIC WORKS DEPARTMENTS | |
| LAST REVISION NOVEMBER 2014 | | |