



NOTES:

ANY CURB STOP LOCATED IN BLACKTOP OR CONCRETE DRIVEWAY OR SIDEWALK SHALL BE COVERED WITH A 10" G.V. BOX TOP SECTION.

ALL WATER SERVICES SHALL BE 1" SDR 11 IPS HDPE BLACK POLY.

CORPORATION SHALL BE A 1" FORD FB 600-4-NL, MCDONALD 74701-B, MUELLER B-25000-N OR OWNER APPROVED ALTERNATE.

CURB STOP AND BOX SHALL BE 1" FORD B22-444-M-NL, MCDONALD 76104, MUELLER B-25154 OR OWNER APPROVED ALTERNATE WITH A STATIONARY ROD AND BE ABLE TO ADJUST FROM 84" TO 96".

WATER SERVICE MUST BE CONTINUOUS WITH NO JOINTS.

SANITARY AND WATER SERVICE LINES SHALL BE INSTALLED IN THE SAME TRENCH WITH 3 FEET OF SEPARATION. WATER SERVICE ON THE UPSTREAM SIDE OF THE SANITARY SERVICE.

CURB BOXES INSTALLED IN AREAS WHERE THE BOULEVARD IS TO BE CUT AT A LATER DATE, TOP OF CURB BOX SHALL BE SAME ELEVATION AS TOP OF CURB.

| | | |
|--|--|-----------------------|
|  | <h2>1" WATER SERVICE WITH HDPE WATERMAIN</h2> | STANDARD PLATE # WM-8 |
| | CITY OF MAPLE GROVE ENGINEERING & PUBLIC WORKS DEPARTMENTS | |
| LAST REVISION NOVEMBER 2014 | | |